

Nordion (Canada) Inc. Event Reporting
For the Quarter (Oct to Dec 2023)

Event Number	Event	Status/Outcome
23-09*	Water main break in Shipping area	A portion of the water main broke, causing some flooding of the outdoor shipping compound. A repair was successfully completed the same day. Nordion staff will be conducting a survey of the water main system to determine if any other sections should be proactively replaced. There were no health or safety impacts from this incident.
23-10*	Late reporting on return sources	A report on receipt of sealed sources was 48 hours late due to an internal email miscommunication. An improvement to the communication process is underway.

** There was no impact to health, safety, environment or security as a result of these events*